

Research

Energy management strategy for a hybrid micro-grid system using renewable energy

Christian Bipongo Ndeke¹ · Marco Adonis¹ · Ali Almaktoof¹

Received: 16 October 2023 / Accepted: 1 February 2024

Published online: 08 February 2024

© The Author(s) 2024 [OPEN](#)

Abstract

This paper introduces an energy management strategy for a hybrid renewable micro-grid system. The efficient operation of a hybrid renewable micro-grid system requires an advanced energy management strategy able to coordinate the complex interactions between different energy sources and loads. This strategy must consider some factors such as weather fluctuations and demand variations. Its significance lies in achieving the overarching objectives of these systems, including optimizing renewable energy utilization, reducing greenhouse gas emissions, promoting energy independence, and ensuring grid resilience. The intermittent nature of renewable sources necessitates a predictive approach that anticipates the energy availability and adjusts the system operation. The aim of this study was to develop an energy management system for a hybrid renewable micro-grid system to optimize the deployment of renewable energy resources and increase their integration in the power system. Therefore, the main objective of this work was to develop an energy management strategy that controls the flow of energy between the hybrid micro-grid system and the load connected directly as well as the load connected to the utility grid using MATLAB/Simulink software. The second objective was to control the charging and discharging of the battery. The results show that the developed algorithm was able to control the energy flow between the hybrid micro-grid system and the utility grid and also to ensure a proper relation between the charging /discharging rate of the battery based on their operating conditions. In this application, the battery was charged at higher power. It was seen that a higher charging power enables to fully recharge the battery in a shorter amount of time than usual. The results have shown that it is possible to maximize the charging time by using a greater power and this algorithm ensures the state of charge (SOC) of battery to remain in the admissible limits (between 20 and 100%).

Keywords Energy management strategy · Hybrid micro-grid · Renewable energy sources · Battery energy storage · Distributed generation

Abbreviations

AC	Alternating current
DC	Direct current
DER	Distributed energy resources
DG	Distributed generation
EMS	Energy management system
ESS	Energy storage system
Kv	Kilo volt

✉ Christian Bipongo Ndeke, ndekechristian@gmail.com; Marco Adonis, AdonisMA@cput.ac.za; Ali Almaktoof, ALMAKTOOFA@cput.ac.za |

¹Department of Electrical, Electronic and Computer Engineering, Cape Peninsula University of Technology, Cape Town 7535, South Africa.



KWh	Kilowatt hour
KWp	Kilowatt peak
MW	Mega watt
PCC	Point of common coupling
PV	Photovoltaic
SOC	State of charge

1 Introduction

The global energy landscape is undergoing a paradigm shift, marked by a heightened focus on sustainability and a transition towards renewable energy sources [1]. Micro-grid systems, characterized by their localized generation and distribution capabilities, have gained prominence as a means to enhance energy resilience and efficiency [2]. Hybrid micro-grid systems combine multiple sources of energy, often integrating conventional and renewable sources, to create a robust and adaptive energy infrastructure. This integration necessitates sophisticated energy management strategies to harness the full potential of diverse energy resources and ensure a reliable power supply. While the integration of renewable energy into micro-grid systems offers many benefits, it introduces challenges that must be addressed for effective implementation. The intermittent nature of renewable sources, variability in energy production, and the mismatch between energy supply and demand pose significant hurdles [3].

Additionally, the integration of diverse energy storage technologies and the seamless coordination of multiple energy sources require advanced control strategies. Addressing these challenges is essential for realizing the full economic and environmental potential of hybrid micro-grid systems [4]. A thorough examination of the existing literature reveals a growing body of research dedicated to the optimization of hybrid micro-grid systems. Studies have explored various aspects, including energy management algorithms, control strategies, and the integration of different renewable energy sources [5]. Different contributions have been made in the areas of predictive modeling, real-time monitoring, and economic dispatch strategies. However, there remains a need for more comprehensive approaches that address the unique challenges of hybrid micro-grid systems, considering both technical and economic factors [6, 7].

This research aimed to contribute to the existing body of knowledge by developing an advanced energy management strategy for hybrid micro-grid systems using renewable energy sources. The study explored the integration of solar, wind, and diesel generator, coupled with a battery energy storage, to create a resilient and efficient energy network. The focus was on addressing challenges related to intermittency, optimizing energy dispatch, and ensuring grid stability. The motivation behind this research lied in the imperative to accelerate the adoption of sustainable energy solutions. By developing a robust energy management strategy for hybrid micro-grid systems, this study provides practical insights for engineers, policymakers, and stakeholders involved in the planning and implementation of renewable energy projects. The potential impact extends beyond theoretical advancements, offering tangible contributions to the transition towards a cleaner and more sustainable energy future.

The primary contribution of this study included an advanced energy management algorithm. Developing an algorithm to optimize the coordination of renewable energy sources and battery energy storage within a hybrid micro-grid. Moreover, the research had the objective to provide practical guidelines for the design and operation of hybrid micro-grid systems, fostering a more widespread adoption of sustainable energy practices. The developed hybrid renewable micro-grid model and energy management system algorithm were performed using the Stateflow logical language in the MATLAB/Simulink environment. This paper is organized as follows. Section 2 presents the concept of hybrid micro-grid. In Sect. 3, the energy management strategy is presented. Section 4 presents and evaluates the simulation results of the developed algorithm and finally, Sect. 5 gives the conclusion of the paper.

1.1 Critic on literature

Hybrid micro-grid systems are becoming more prevalent and are finding more interesting applications in different fields. A hybrid micro-grid system is composed of different generation resources including fossil fuel-based (e.g., diesel) and renewable energy-based resources such as solar PV, micro-hydro, wind and biomass. The role of a hybrid micro-grid system is of paramount importance in the current complex energy transition. Hybrid micro-grids are increasingly being adopted worldwide. They can operate in grid connected and island mode. Except for the distributed generation units, a hybrid micro-grid is composed of controllable load and energy storage systems. An energy management system is

important to optimize its performance. The energy management system of a micro-grid includes both generation and demand side management by providing satisfaction of the system constraints, to realize an economical, sustainable, and reliable operation of the micro-grid. An energy management system offers many benefits from production dispatch to energy savings, reactive power support to the regulation of frequency, reliability to loss cost-reduction, energy balance to mitigate greenhouse gas emissions, and customer participation to customer privacy. As the level of the renewable energy sources penetration raises, the requirement of a real-time and robust energy management strategy becomes necessary to connect the distribution generation resources as well as the energy storage systems.

1.2 Existing works related to energy management system of hybrid micro-grid system

A brief overview on the energy management system of hybrid micro-grid system using renewable energy sources is outlined below:

1. Himabindu et al. have developed an optimal energy management strategy. The main objective of the research was to satisfy the power demand by the load and to maintain the state of the charge of the energy storage systems, which included the battery and the hydrogen in a certain range. The results have shown that the method was able to optimize the utilization costs and the lifespan of the energy storage systems. The authors suggested the utilization of other methods to check the performance of the proposed energy management system and also include the grid-connected mode [8].
2. Kang et al. [9] have proposed a small-scale hybrid AC/DC microgrid energy management technique based on Artificial Neural Network control. An EMS operation mode was chosen, an operation profile was chosen in each operation mode, and then ANN training was implemented in each operation mode in order to develop the proposed EMS.
3. Elkazaz et al. [10] have implemented a new energy management system (EMS) that can minimize the micro-grid daily operating cost and maximize the renewable energy source self-consumption by determining the optimal configuration for a central battery energy storage system (BESS) based on a defined cost function was proposed. This EMS had a two-layer structure. Firstly, the upper layer. In this structure a Convex Optimization Technique was used to solve the optimization issue and to determine the reference values for the power that should be drawn by the micro-grid from the main grid utilizing a 15 min sample time. The reference values were then fed to a lower control layer, which uses a 1 min sample time, to determine the settings for the BESS which then ensured that the micro-grid accurately follows these references.
4. Bilbao et al. [11] focused on the optimal operation of hybrid microgrids, based generally on the mathematical modelling. To implement the management of this type of networks requires several challenges and various options. The main contribution of the research was the mathematical modelling of many hybrid microgrid components. This modelling can be utilized in various control and management methods of the network, and its feasibility has been shown in three methods, which include one based on the Decision Tree method, which belongs to the Machine Learning family. The results on a test system of 69 buses showed that it is possible to implement its management.
5. A new hybrid battery and PV-wind turbine power system was proposed by Reddy et al. [12] using Fuzzy Logic control. The dynamic behaviour of the recommended model was examined under various operating conditions. The developed system and its control strategy displayed exceptional performance. The proposed model offers a useful tool for enhancing the efficiency of the smart grid.

However, the study done by Lanre Olatomiwa et al. [13] provided a review on energy management system in hybrid renewable energy systems. In this research, particular consideration was focused on smart grids energy management systems. The methods using fuzzy logic techniques are also presented to develop the energy management systems. The study pointed out that the requirement for a real-time and effective energy management strategies has become very vital to connect the hybrid renewable resources associated with the energy storage systems. This complete review revealed that most of studies on the energy management for a hybrid renewable energy systems have been done in islanded mode, and only a few cases are focused on grid connected. Thus, it is important to develop new strategies and techniques to control and to manage the power flow in a hybrid renewable micro-grid system operating in grid connected mode.

2 Concept of hybrid micro-grid

A typical hybrid micro-grid system refers to a group of distributed generation (DG) systems based on renewable and/or non-renewable resources, including an energy storage system (ESS) as well as local controllable loads, usually connected to the distribution system [14]. It can either operate in grid connected mode or island mode according to the load condition. Hybrid micro-grid systems can be classified in different categories based on the location, size, application, and connectivity [15]. Three types of hybrid micro-grid configurations exist in general, which are remote, grid-connected and networked. Hybrid micro-grid systems can be principally classified into three categories according to the system architecture and voltage characteristics, AC micro-grid, DC micro-grid, and Hybrid AC/DC micro-grid [16].

A hybrid micro-grid is composed of different distributed generation sources; the power from these DGs is collected, converted and distributed based on the load demands. To assure an effective operation of the system, a control strategy is required and it is important when power electronics interface with the system to constitute a single unit. The control system is very important because it also enables to conserve the specific energy supply and the power quality [17]. Figure 1 gives a typical representation of a hybrid micro-grid system, where it can be seen that a micro-grid could also be interconnected with the main grid and includes a diversity of assets and power sources, which provide different services to a range of facilities.

According to the environmental concerns (like atmospheric, ground and water pollution, climate change), the use of fossil fuels, the finite and limited quantities of conventional fuels, the increase in the cost of electrical energy, the need of energy security and the independence of certain nations, increase the necessity to embrace and develop renewable energy resources [18]. The decentralization of electricity supply brings production closer to the point of consumption, increasing system reliability, because when a fault occurs somewhere and as a part of the network is insulated, this will not affect the other branches. Additionally, it increases the efficiency of the entire system because the transmission losses are reduced [19].

Hybrid micro-grid systems are getting more attentions due to the increase in energy needs around the world, with a variable rate between nations and continents. For practical and scientific advantages, important incentives are established to promote the integration of hybrid micro-grid projects for electrification in remote areas and developing nations [20]. To improve the power generating system overall, the hybrid micro-grid depends on the interconnect converter. It also enhances the quality of the power and facilitates the AC or DC power supply between each micro-grid [21].

2.1 Architecture of a hybrid micro-grid system

In the pursuit of a resilient, sustainable, and decentralized energy system, hybrid micro-grid architectures have emerged as a cutting-edge solution that integrates the benefits of diverse distributed energy resources, storage technologies, and intelligent control systems. Figure 2 shows the structure of a hybrid micro-grid. The basic architecture includes a variety of

Fig. 1 Hybrid micro-grid concept [17]





Fig. 2 Micro-grid architecture [24]



renewable energy sources, a conventional generator and different types of loads as well as energy storage devices, which interface with the power electronic systems [22]. For a proper system harmonization and control, the Point of Common Coupling (PCC) defines the operating mode, which can be either grid connected mode or islanded mode. It also allows to connect the micro-grid with the main grid. The PCC has as role to connect or disconnect the hybrid micro-grid system from, or to the main grid. To ensure overall system stability, different levels of control, utilizing micro-sources and central controllers support and coordinate the micro-grid [23].

A hybrid micro-grid architecture represents an innovative approach to energy distribution and management that harmonizes renewable and conventional energy sources, storage technologies, and advanced control systems [25]. Hybrid micro-grids are at the forefront of the global movement to change the energy landscape because they promote the local energy production, improve grid resilience, and contribute to environmental sustainability [26]. Hybrid micro-grids have a compelling potential to shape a more efficient and sustainable energy future as technology advances and the understanding of energy dynamics expands [27]. An energy management system (EMS), which is software-based, manages and controls the flow of energy in a hybrid micro-grid system. It collects real-time data from multiple sensors, such as solar panels, wind turbines, and energy storage devices, and evaluates it to determine the best way to operate the system.

2.2 Energy management controls for hybrid micro-grid

For reliable, sustainable, and efficient energy systems, hybrid micro-grids have emerged as a transformative solution that uses the cooperation of diverse energy sources and storage technologies [28]. For a successful operation of hybrid micro-grids, it is important to implement sophisticated energy management controls [29]. These controls serve as the brains behind the system, coordinating the complex interaction of renewable and conventional energy resources, storage systems, and load demands to optimize the performance, resilience, and environmental impact [30].

Energy management controls for hybrid micro-grids are dynamic, adaptive systems that include a range of hardware and software components designed to monitor, analyze, and direct the flow of energy within the micro-grid. At their core, these controls aim to achieve several key objectives. Different control strategies of the energy management are presented below.

2.2.1 Optimal resource allocation

Hybrid micro-grids often consist of diverse energy sources, including solar PV, wind turbines, fossil fuel generators, and energy storage. The energy management controls determine the most efficient combination of these resources to meet the current energy demand while considering factors such as availability, cost, and environmental impact [31].

2.2.2 Load balancing

The controls actively balance the energy supply and demand by adjusting the distribution of power from different sources. This ensures that the micro-grid operates smoothly, avoiding overloading or underutilization of any particular component [32].

2.2.3 Islanding and grid connection

One of the unique features of hybrid micro-grids is their ability to switch between grid-connected and islanded modes. The energy management controls monitor grid conditions and initiate a seamless transition between these modes as needed, ensuring continuity of power supply and maintaining stability [33].

2.2.4 Storage management

Energy storage systems, such as batteries, play a pivotal role in hybrid micro-grids by storing excess energy and releasing it when demand exceeds supply. The controls determine the optimal times for charging and discharging these storage systems to maximize their lifespan and efficiency [34].

2.2.5 Predictive analytics

Advanced energy management controls use predictive algorithms that anticipate the energy generation, consumption patterns, and storage needs based on historical data, weather predictions, and load profiles [35]. This enables proactive decision-making and enhances the ability of micro-grid to adapt to changing conditions [36].

2.2.6 Demand response

The controls can also facilitate demand response strategies by intelligently adjusting energy consumption in response to grid conditions or pricing signals [37]. This not only benefits the micro-grid but also contributes to overall grid stability during peak demand periods [38].

2.2.7 Environmental considerations

Energy management controls can factor in environmental considerations, such as reducing carbon emissions, when making operational decisions. This ensures that the operation of micro-grid aligns with sustainability goals [39].

The complexity of hybrid micro-grid systems demands a multidisciplinary approach to energy management controls [40]. This involves a fusion of control theory, power electronics, data analytics, communication protocols, and real-time monitoring. As technology continues to advance, artificial intelligence and machine learning techniques are increasingly being integrated into energy management systems to enhance their adaptability and decision-making capabilities [41].

2.3 Description of the developed hybrid microgrid system

The developed hybrid micro-grid architecture was applied to supply a variable AC load. The power generation capacity of each distributed generation source was 500 kWp for solar, 500 kW for wind energy, 900 kWh for the battery and 1.5 MW for the diesel generator. The power generated from the PV and battery are DC, but for wind is AC, therefore,




Fig. 3 Block diagram of the developed system

Table 1 Required values for the developed system

System	Capacity	Number of unit	Total
PV power plant	500 kW _p	1	500 kW _p
Wind power plant	500 kW	1	500 kW
Battery	900 kWh	1	900 kWh
Diesel generator	1.5 MW	1	1.5 MW
AC Load	800 kW	1	800 kW

the power generated from the DC sources were converted in AC by using an inverter. The line to line voltage from PCC was 10 kV and a transformer was used to set the AC bus voltage for the system to 380 Vac. The battery was utilized to assure power supply to the variable load without any interruption. It supplied power when the available power from the distributed generation was not sufficient to satisfy the load.

2.3.1 Load profile

The developed hybrid micro-grid supplied the load directly by 380Vac through a transformer. The power system grid included generation, transmission, and distribution. According to the generation system, the total generated power, such as PV and Wind, were connected in parallel. The battery was used as a back-up system during peak demand and fluctuations in the power generated from renewable energy sources. Figure 3 illustrates the block diagram of the developed system and Table 1 presents the summary of all the variables for the developed hybrid micro-grid.

3 Energy management strategy for the developed hybrid micro-grid

The system consisted of two renewable energy sources (wind and PV power plants), an energy storage system, and a generator that supplied electricity to the load demand when the utility grid was unavailable. The following formula in Eq. (1) was used to determine the net power generation:

$$P_G = P_{pv} + P_{wind} + P_{batt} \quad (1)$$

where, P_G the power generation; P_{pv} the power produced from PV; P_{wind} the power produced from Wind; P_{batt} the power produced from Battery.

When there was an excess of power generation, the battery was charged; when there was not enough power generation to meet the load demand, the battery was discharged. According to the developed energy management system (EMS), the power generation was supplied the load demand through four scenarios and with the help




Fig. 4 Flowchart of the energy management strategy for the hybrid microgrid

of the battery, a diesel generator, and the utility grid. Figure 4. shows the architecture of the energy management algorithm flow chart. First, the power generated by various sources and the load demand was measured using the scenarios listed below.

Case 1: When the load demand is met by the power generated.

$$P_L = P_{pv} + P_{wind} \quad (2)$$

According to this scenario, the load was continuously supplied by the power generated from wind power plant and PV power plant sources as illustrated in Eq. (2).

Case 2: When the power generation was greater than the load demand.

$$P_{pv} + P_{wind} > P_G \quad (3)$$

In this case, the power generation exceeded the load demand as presented in Eq. (3); as a result, the load demand was satisfied by the power generation, and the surplus was used to charge the battery. The SOC of the battery was firstly measured and see if it fell below the maximum value, which was 100%. When the condition was satisfied, the load was supplied and the battery was also connected to be charged until its SOC reached the maximum value. When the battery was fully charged, it was disconnected and waited the discharge phase as presented in Eqs. (4), (5), which show the charging condition. The excess of production was supplied to the utility grid. The conditions were formulated as below:

$$SOC_{min} < SOC_{batt} < SOC_{max} = 20\% < SOC_{batt} < 100\% \quad (4)$$

$$P_G > P_L = \text{Charging} \quad (5)$$

Case 3: when the power generation is not enough to meet load demand as presented in Eq. (6).

$$P_{pv} + P_{wind} < P_G \quad (6)$$

The battery was used to supply the load, in this case because the power generation was less than what was required to meet the load demand as shown in Eqs. (6), (7) give the condition of discharge. The energy management system (EMS) calculated and checked the difference between the available power generation from the renewable energy sources and load. It also measured the SOC of the battery at the same time. When the power from the battery was sufficient to meet the demand of the load, when the condition was satisfied, then the battery was discharged until its SOC reached the minimum point. In Eq. (8), the supply power formula is given where the battery is used to support the load. Equations (9), (10) and (11) presents the operating modes of the battery.

$$P_G < P_L = \text{Battery Discharging} \quad (7)$$

$$P_L = P_{pv} + P_{wind} + P_{batt} \quad (8)$$

$$SOC_{batt} = 20\% = \text{Battery Disconnected} \quad (9)$$

$$SOC \leq 20\% = \text{Charge battery} \quad (10)$$

$$SOC > 20\% = \text{Discharge battery} \quad (11)$$

Case 4: When the battery reached its minimum value and the generated power was less than the load demand.

$$P_{pv} + P_{wind} + P_{batt} < P_L \quad (12)$$

In this case, the SOC of the battery reached its minimum value, which was 20% thus, the battery was disconnected and Eq. (12) presents the formula of the power supplied with the support of the battery when this total amount becomes less than the demand of the load. At this stage, the load demand was provided by the help of the generator or the utility grid based on the availability of the utility grid. When the utility grid was available, then the utility grid

supplied the load and when the utility grid was not available, then the diesel generator was switched on to supply the load. The EMS checked the availability of the generated power from the renewable energy sources to see if it was $\geq 20\%$ of the total power produces from the renewable energy sources. When the condition was approved, then the battery was connected to be charged by the available power generation. In contrary, when the condition was not satisfied, then the available generated power from the renewable energy sources was added to the utility grid or generator to supply the load. For this study, it was specified that the battery could be charged when the available power was $\geq 20\%$ of the total production, when it reached its minimum value. Charging a battery with a greater power input, compared to a smaller one, offers several advantages in terms of efficiency, charging time, and overall battery performance. The flow chart architecture of the EMS is presented in the Fig. 4 below.

4 Simulation results

The developed energy management system algorithm was designed and built on MATLAB/SIMULINK environment by physical modelling. The Stateflow logical programming environment was used to design the energy management system algorithm. All the components of the model were represented by their respective model blocks available in Stateflow logical programming environment. This section is focused on the different simulation results of the developed energy management system algorithm and considers various scenarios. Adopting scenarios allows to position with a neutral and objective point of view while also better understanding the real environment. Scenarios are essential for providing a clear technique and strategy. As a result, considering the scenarios in chronological order offers a very helpful direction. The Stateflow logical programming environment is used in the implementation of the developed energy management system algorithm. The operational mode of Stateflow environment refers to a logical system that can be either 0 or 1. When the output of the flow chart reads 1, it signifies the system is operational (ON), and when it reads 0, it means the system is OFF. The test parameters for each component used in the simulation are presented in the Table 2.

Table 2 Test parameters used for the MATLAB simulation

Parameter	Symbol	Value
Inverter rated output voltage	V_o	380 V
MPPT voltage	V_{MPPT}	800 V
Cell temperature	T	25 °C
Sun irradiance	I_r	250, 500, 1000 W/m ²
PV max power	P_{PV_max}	500 kW _p
Wind turbine speed	N_s	13 rad/s
Wind max power	P_{wind_max}	500 kW
Wind turbine torque	T_r	13,000 Nm
Wind voltage	V_{conv}	800 V
Nominal battery voltage	V_{nom_batt}	1000 V
Nominal battery capacity	BAh	900 Ah
Inverter rated power	S_B	1 MVA
Diesel generator rated power	S_G	1.5 MVA
Grid frequency	f_g	50 Hz
Switching frequency	f_{sw}	30 kHz
DC Link capacitor	C_{DC}	0.1 μH
Grid side inductor	L_g	18.4 μH
Inverter side inductor	L_i	22.99 μH
Filter capacitance	C_f	1.11 mF
Damping resistance	R_f	3.123 m Ω
Resonance frequency	f_{res}	47.29 Hz
Approximated total inductor resistance	R_T	0.1
PLL settling time	T_{SPLL}	2.25 ms
Load reference power	P_{ref}	800 kW




Fig. 5 Power generated by renewable energy sources

Scenario 1: In this first case, the power production from the renewable energy sources was equal to the total load power demand. As shown in Table 1, the load power was fixed at 800 kW. Thus, the total power generated from the renewable energy sources was supplied to the load without any interruption and in this stage, the battery, utility




Fig. 6 Stateflow output results chart

Fig. 7 Power generated by renewable energy sources





Fig. 8 Stateflow output results chart

grid and diesel generator were disconnected from the system. Figure 5 below illustrates the power generation from the renewable sources, which are PV and wind.

As it can be seen in Fig. 5, the power generated is equal to the load demand power. Figure 6 presents the chart of the output results for this first scenario, in which all the results are displayed graphically. It is shown that only the load is supplied and other outputs, which include the battery, utility and diesel generator are not operational.

Scenario 2 In this second case, the total power generation from the renewable energy sources became higher than the load demand power. As shown in Fig. 7, the power produced from the renewable energy sources is more than the expected load demand power. Thus, the battery is charging according to the charge / discharge condition and when the maximum value was reached then it was automatically disconnected from the system and the excess of production was directed to the utility grid.

Figure 8 presents the graphical output results from the block diagram, showing the operating mode of the system. The result shown that the battery is charging and at the same time the load is being supplied.

In Fig. 9 below, the battery is fully charged. Therefore, it was disconnected and the surplus of production was directed to the utility grid. In this case, the load demand and utility grid were completely supplied until the production condition change.




Fig. 9 Battery fully charged




Fig. 10 Stateflow output results chart

Fig. 11 Power generated by renewable energy sources




Figure 10 also shows the output results from the Stateflow chart in which all the outputs (variable AC load, battery, utility grid and diesel generator) are presented. It is shown that the two outputs are operational, the load demand and the utility grid. This shows that the battery is fully charged and waiting for the discharging phase.

Scenario 3 In this third case, the power generated from the renewable energy sources became less than the load demand power as illustrated in Fig. 11, thus, the load demand was met by the assistance of the battery energy storage.

In Fig. 12, it is shown that the battery was at its maximum value (100%) and it is discharging according to the stated condition. In this case, the battery was discharged until it reached its minimum value (20%) or the condition changed.

Figure 13 shows the stateflow chart, where the output results are displayed. The first and second graphs show that the load and the battery are in operating mode and the two other outputs, which are the utility grid and diesel generator are disconnected. In Fig. 14, the state of charge of the battery is presented. It shows that the battery has reached its minimum value (20%) and was automatically disconnected from the system. In this stage, according to the developed energy management system, the load demand was met by the help of the utility grid or diesel generator based on the utility grid availability.

When the battery reached its minimum value, the condition was that, if the utility grid was available, then the load was supplied by the utility grid and if not, the diesel generator was switched on to supply the load. Additionally, the




Fig. 12 Battery discharging




Fig. 13 Stateflow output results chart




Fig. 14 Battery discharged and disconnected from the system

developed energy management strategy stated that the battery could only be charged if the power generated from the renewable energy sources was more or equal to 20% of the total produced power from these sources. The total power produced from the renewable energy sources was 1 MW and 20% of this production was 200 kW, thus, the battery could only be charged when the power generation was ≥ 200 kW. This condition of charging a battery with a higher power input, compared to a smaller one, offers several advantages in terms of efficiency, charging time, and overall battery performance.





Fig. 15 Stateflow output results chart

The Stateflow chart is shown in Fig. 15, where the output results are displayed. The load was supplied by the assistance of the utility grid and the available power supplied from the renewable sources. The battery was charging through the power generated from the renewable energy sources because the power generated from the renewable energy source exceeded 20% of the total power produced in this case. When the power generated from the renewable energy sources dropped below 20% of the total power generated, which means below 200 kW as illustrated in Fig. 16, the battery was assumed to be automatically disconnected from the system as defined from the algorithm and it is shown in Fig. 17.

Figure 17 shows the Stateflow chart, where the output results of this case are presented. It is seen that the system is operating on grid connected mode and the battery is disconnected from the system.

When the utility grid became unavailable, the diesel generator was switched on to supply the load as shown in Fig. 18. The load was supplied through the diesel generator and the available power produced from the renewable energy sources. The battery was charging at the same time because the generated power from the renewable energy sources was more or equal to 20% of the total power generated (≥ 200 kW).

Fig. 16 Power generation by renewable energy sources






Fig. 17 Output results from the developed energy management system chart




Fig. 18 Stateflow output results chart

The output results from the Stateflow chart is presented in the Fig. 18 above. The results show that the load, battery and diesel generator graphs are in operating mode (1) and the utility grid graph is (0), which shows that the utility grid is unavailable. As discussed for the utility grid availability case, when the power generated from the renewable energy sources became less than 20% of the total power generated, which means below 200 kW as illustrated in Fig. 19, then the battery was automatically disconnected from the system and only the load demand was supplied from the available power produced and diesel generator.




Fig. 19 Power generation by renewable energy sources




Fig. 20 Stateflow output results chart

Figure 20 shows the Stateflow chart, where the output results of the presented case are shown. It is seen that the load is supplied through the diesel generator and the battery is disconnected from the system because the power generated is less than 20% of the total power produced from the renewable energy sources.

The demand was supplied via the diesel generator, and the developed energy management strategy was continuously checking the power produced from the renewable energy sources and the utility grid availability. Once the power generated was enough to provide power to the load demand or the utility grid became available, then the diesel generator was switched off. This developed algorithm enabled to provide the variable AC load with uninterrupted power and to keep

the SOC of the battery in the admissible limits by charging the battery at higher power. In this application, because of the intermittent nature of the renewable resources, a higher charging power is required to fully recharge the battery in a shorter amount of time than usual. The results have shown that it is possible to maximize the charging time by using a greater power. Moreover, a higher power charging of a battery has presented a better energy density utilization. By utilizing the developed control rules for the hybrid renewable microgrid, the system achieved power balance and the battery SOC maintained the required value for extending the battery life.

5 Conclusion

This paper presented an energy management strategy for hybrid microgrid system using renewable energy. Different scenarios were used during the simulation to show the robustness and the effectiveness of the developed energy management system control to handle the load in both islanded mode and grid connected mode and ensure the proper operation of the battery energy storage system in hybrid microgrid system. The variable AC load for the developed hybrid microgrid system was fixed to 800 kW and the total generation power from the renewable energy sources was 1 MW. To achieve the aim and objectives of the research, a hybrid microgrid model was implemented and developed using MATLAB/Simulink software and an energy management system algorithm was developed using Stateflow logical programming environment in MATLAB/Simulink software. The energy management strategy dictated that the battery can only charge if the generated power from renewable sources is equal to or greater than 20% of the total production. The overall power supply from renewable sources is 1 MW, and 20% of this amount is 200 kW. Hence, the battery can only charge when the power production is ≥ 200 kW. This condition of charging the battery with a higher power input, offers various advantages in terms of efficiency, charging time, and overall battery performance compared to a scenario with a smaller input. The results show that this developed algorithm was able to control the energy flow between the hybrid micro-grid system and the variable AC load directly connected as well as connected to the utility grid and also to ensure a proper relation between the charging/discharging rate of the battery energy storage system based on their operating conditions and finally, it allowed to keep the SOC of battery in the admissible limits. To improve the overall reliability of the system, more research in this area is necessary. In this study, excess energy was stored in the battery and then sent to the utility grid because renewable sources sometimes produce more energy than the load demands. Developing an energy management plan that maximizes the use of this extra energy is advised. Examples of such loads include water pumping, ambient heating or air conditioning, and water heating with storage tanks.

Author contributions As Corresponding Author, I confirm that the manuscript has been read and approved for submission by all the named authors. The first author listed is CBN, since it is expected of him to make the greatest contribution to the project data acquisition, analysis thereof and conceptualization of a practical working energy management strategy testing model. Second and third authors are Dr MA and Dr AA, since they are an integral part of guidance, revision, and quality control during this project.

Funding There has been no significant financial support for this work that could have influenced its outcome.

Data availability The datasets used can be accessed by request from the corresponding author.

Declarations

Ethical approval and consent to participate The data collection for this project did not require the consent of participants since humans or animals are not the subject of research.

Competing interests We know of no competing of interests associated with this publication.

Open Access This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons licence, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons licence, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons licence and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this licence, visit <http://creativecommons.org/licenses/by/4.0/>.

Appendix 1

Energy management system condition table

Descriptions	Conditions	1	2	3	4	5	6	7
Scenario 1 ($P_G = P_L$)								
Supply variable AC Load	$P_G = P_L$	1	0	0	0	0	0	0
Scenario 2 ($P_G > P_L$)								
Supply variable AC Load and Charge Battery	$SOC < 100\%$	0	1	0	0	0	0	0
Supply variable AC Load and Utility grid	$SOC = 100\%$	0	0	1	0	0	0	0
Scenario 3 ($P_G < P_L$)								
Discharge battery	$SOC > 20\%$	0	0	0	1	0	0	0
Disconnect battery	$SOC \leq 20\%$	0	0	0	0	1	0	0
Connect the utility grid if it is available	Utility grid availability = 1	0	0	0	0	0	1	0
Switch on the diesel generator if the utility grid it is unavailable	Utility grid availability = 0	0	0	0	0	0	0	1

Bold values represent active state of the system

Appendix 2

Energy management system action table

N*	Descriptions	Actions
1	Variable AC Load supplied	A1: AC Load = ON ;
2	Variable AC Load supplied & Battery charging	A2: AC Load & Battery = ON ;
3	Variable AC Load & Utility grid supplied	A3: AC Load = ON ; Battery = OFF ; Utility grid = ON ;
4	Battery discharging	A4: AC Load = ON ; Battery = ON ;
5	Battery disconnected	A5: Battery = OFF ;
6	Utility grid connected	A6: AC Load = ON ; Utility grid = ON ;
7	Diesel generator switched on	A7: AC Load = ON ; Diesel generator = ON ;

Bold values represent active state of the system

References

- Aljohani TM, Ebrahim AF, Mohammed O. Hybrid microgrid energy management and control based on metaheuristic—driven vector-decoupled algorithm considering intermittent renewable sources and electric vehicles charging lot. *Energies*. 2020;13(13):3423.
- Sayeed F, et al. A novel and comprehensive mechanism for the energy management of a hybrid micro-grid system. *Energy Rep*. 2022;8:847–62.
- Liu X, Zhao T, Deng H, Wang P, Liu J, Blaabjerg F. microgrid energy management with energy storage systems: a review. *CSEE J Power Energy Syst*. 2023;9(2):483–504.
- Kumar GVB, Palanisamy K. Energy management of renewable energy-based microgrid system with HESS for various operation modes. *Front Energy Res*. 2022;10(October):1–21.
- Zia MF, Elbouchikhi E, Benbouzid MEH. An energy management system for hybrid energy sources-based stand-alone marine micro-grid. *IOP Conf Ser Earth Environ Sci*. 2019;322(1):012001.
- Arunkumar AP, Kuppusamy S, Muthusamy S, Pandiyan S, Panchal H, Nagaiyan P. "An extensive review on energy management system for microgrids. *Energy Sourc Part A Recover Util Environ Eff*. 2022;44(2):4203–28.
- Helal SA, Najee RJ, Hanna MO, Shaaban MF, Osman AH, Hassan MS. An energy management system for hybrid microgrids in remote communities. *Can. Conf. Electr. Comput. Eng.*, pp. 1–4, 2017.
- Himabindu E and Gopichand NM. "Energy Management System for grid integrated microgrid using Fuzzy Logic Controller." 2020 IEEE 7th Uttar Pradesh Section International Conference on Electrical, Electronics and Computer Engineering, 2020.
- Kang KM, et al. Energy management method of hybrid ac/dc microgrid using artificial neural network. *Electron*. 2021;10(16):1939.

10. Elkazaz M, Sumner M, Thomas D. Energy management system for hybrid PV-wind-battery microgrid using convex programming, model predictive and rolling horizon predictive control with experimental validation. *Int J Electr Power Energy Syst.* 2020;115:105483.
11. Bilbao J, Bravo E, García O, Rebollar C, Varela C. Optimising energy management in hybrid microgrids. *Mathematics.* 2022;10(2):214.
12. Reddy CR, Rani BG, Kondalu M, Sekhar OC, Venu G, Kalyan CNS. "Energy Management System for Hybrid Renewable Energy-Based Microgrid. *INDICON 2022 - 2022 IEEE 19th India Counc. Int. Conf., 2022.*
13. Olatomiwa L, Mekhilef S, Ismail MS, Moghavvemi M. Energy management strategies in hybrid renewable energy systems: a review. *Renew Sustain Energy Rev.* 2016;62:821–35. <https://doi.org/10.1016/j.rser.2016.05.040>.
14. Agrawal M, Mittal A. Micro grid technological activities across the globe: A review. *Int J Res Rev Appl Sci.* 2011;7(May):147–52.
15. Lotfi H, Khodaei A. AC versus DC microgrid planning. *IEEE Trans Smart Grid.* 2017;8(1):296–304.
16. Ahmed M, Meegahapola L, Vahidnia A, Datta M. Stability and control aspects of microgrid architectures-a comprehensive review. *IEEE Access.* 2020;8:144730–66.
17. Totem E. *Microgrids and First Nations.* 2019.
18. Chowdhury S, Chowdhury SP, Crossley P. *Microgrids and active distribution networks.* 2009.
19. Jones GW, Chowdhury BH. "Distribution system operation and planning in the presence of distributed generation technology. *Transm. Distrib. Expo. Conf. 2008 IEEE PES Powering Towar. Futur. PIMS 2008, no. June, 2008.*
20. Hirsch A, Parag Y, Guerrero J. Microgrids: a review of technologies, key drivers, and outstanding issues. *Renew Sustain Energy.* 2018;90:402–11.
21. Carpintero-Rentería M, Santos-Martín D, Guerrero JM. Microgrids literature review through a layers structure. *Energies.* 2019;12(22):1–22.
22. Bhavaraju V, Yang Y, Buck EF. Distributed energy resource control and utility interconnection management. *Industry Appl Magazine.* 2022;28(5):38.
23. Altaf MW, Member GS. Microgrid protection challenges and mitigation approaches — a comprehensive review. *IEEE Access.* 2022;10:38895–922.
24. Han Y, Zhang K, Li H, Coelho EAA, Guerrero JM. MAS-based distributed coordinated control and optimization in microgrid and microgrid clusters: a comprehensive overview. *IEEE Trans Power Electron.* 2018;33(8):6488–508.
25. Kishore PM, Ravikumar B. Refined hybrid microgrid architecture for the improvement of voltage profile. *Energy Procedia.* 2016;90:645–54.
26. Choudhary MSMK. IRJET-Architectures and overview of hybrid micro-grid. *Irjet.* 2021;8(3):2275–81.
27. Azeem O, et al. A comprehensive review on integration challenges, optimization techniques and control strategies of hybrid ac/dc microgrid. *Appl Sci.* 2021;11(14):6242.
28. Elmouatamid A, Ouladsine R, Bakhouya M, Kamoun NEI, Khaidar M, Zine K. Review of control and energy management approaches in micro-grid systems. *Energies.* 2021;14(1):168.
29. Ahmad S, Shafiuallah M, Ahmed CB, Alowaiifeer M. A review of microgrid energy management and control strategies. *IEEE Access.* 2023;11:21729–57.
30. Allwyn RG, Al-Hinai A, Margaret V. A comprehensive review on energy management strategy of microgrids. *Energy Rep.* 2023;9:5565–91.
31. Kreishan MZ, Zobaa AF. Optimal allocation and operation of droop-controlled islanded microgrids: a review. *Energies.* 14: 15. 2021.
32. Ortiz L, Orizondo R, Águila A, González JW, López GL, Isaac I. Hybrid AC/DC microgrid test system simulation: grid-connected mode. *Heliyon.* 2019. <https://doi.org/10.1016/j.heliyon.2019.e02862>.
33. Antalem DT, Muneer V, Bhattacharya A. Decentralized control of islanding/grid-connected hybrid DC/AC microgrid using interlinking converters. *Sci Technol Energy Transit.* 2022;77:7.
34. Bharatee A, Ray PK, Subudhi B, Ghosh A. Power management strategies in a hybrid energy storage system integrated AC/DC microgrid: a review. *Energies.* 2022;15(19):7176.
35. Abadi SAGK, Habibi SI, Khalili T, Bidram A. A model predictive control strategy for performance improvement of hybrid energy storage systems in DC microgrids. *IEEE Access.* 2022;10:25400–21.
36. Joshal KS, Gupta N. Microgrids with model predictive control: a critical review. *Energies.* 2023;16(13):4851.
37. Saxena A, Kumar S, Shankar R, Parida SK. "Demand response strategy in a multi-microgrid integrating renewable sources for improved frequency regulation", 2022 IEEE IAS Glob. Conf Emerg Technol GlobConET. 2022;2022:77–83.
38. Mina-Casaran JD, Echeverry DF, Lozano CA. Demand response integration in microgrid planning as a strategy for energy transition in power systems. *IET Renew Power Gener.* 2021;15(4):889–902.
39. Ahmad A, Shafiuallah M, Ahmed CB, Alowaiifeer M. A review of microgrid energy management and control strategies. *IEEE Access.* 2023;11(January):21729–57.
40. Murty VVSN, Kumar A. Ti Multi-objective energy management in microgrids with hybrid energy sources and battery energy storage systems. *Rev Afr Political Econom.* 2018. <https://doi.org/10.1080/03056244.2018.1546429>.
41. Bihari SP, et al. A Comprehensive review of microgrid control mechanism and impact assessment for hybrid renewable energy integration. *IEEE Access.* 2021;9:88942–58.